

Client Sample Results

Client: Housatonic Basin Sampling & Testing
 Project/Site: Great Barrington Fire Dist-1113000

Job ID: 810-30476-1

Client Sample ID: POE Post Green River PH 01G

Lab Sample ID: 810-30476-1

Date Collected: 07/12/22 09:47

Matrix: Drinking Water

Date Received: 07/14/22 09:00

PWSID Number: 1113000

Method: 331.0 - Perchlorate (LC/MS/MS)


Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perchlorate	0.10		0.050	0.012	ug/L			07/20/22 03:09	1

Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorooctanesulfonic acid (PFOS)	0.57	J	1.9	0.38	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluoroundecanoic acid (PFUnA)	ND		1.9	0.47	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluorohexanoic acid (PFHxA)	ND		1.9	0.38	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluorododecanoic acid (PFDoA)	ND		1.9	0.38	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluorooctanoic acid (PFOA)	ND		1.9	0.38	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluorodecanoic acid (PFDA)	ND		1.9	0.47	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluorohexanesulfonic acid (PFHxS)	ND		1.9	0.47	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluorobutanesulfonic acid (PFBS)	ND		1.9	0.38	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluoroheptanoic acid (PFHpA)	ND		1.9	0.38	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluorononanoic acid (PFNA)	ND		1.9	0.47	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluorotetradecanoic acid (PFTeDA)	ND		1.9	0.57	ng/L		07/25/22 11:13	07/27/22 23:18	1
Perfluorotridecanoic acid (PFTTrDA)	ND		1.9	0.47	ng/L		07/25/22 11:13	07/27/22 23:18	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND		1.9	0.47	ng/L		07/25/22 11:13	07/27/22 23:18	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND		1.9	0.57	ng/L		07/25/22 11:13	07/27/22 23:18	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND		1.9	0.47	ng/L		07/25/22 11:13	07/27/22 23:18	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND		1.9	0.47	ng/L		07/25/22 11:13	07/27/22 23:18	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND		1.9	0.47	ng/L		07/25/22 11:13	07/27/22 23:18	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND		1.9	0.58	ng/L		07/25/22 11:13	07/27/22 23:18	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C2 PFHxA	95		70 - 130				07/25/22 11:13	07/27/22 23:18	1
13C2 PFDA	94		70 - 130				07/25/22 11:13	07/27/22 23:18	1
13C3 HFPO-DA	92		70 - 130				07/25/22 11:13	07/27/22 23:18	1
d5-NEtFOSAA	80		70 - 130				07/25/22 11:13	07/27/22 23:18	1

Method: PFAS6 - PFAS6

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
PFAS Total	ND		2.00	0.500	ng/L			07/28/22 15:42	1



Surrogate Summary

Client: Housatonic Basin Sampling & Testing
 Project/Site: Great Barrington Fire Dist-1113000

Job ID: 810-30476-1

Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Matrix: Drinking Water


Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		PFHxA (70-130)	PFDA (70-130)	HFPODA (70-130)	d5NEFOS (70-130)
810-30476-1	POE Post Green River PH 01G	95	94	92	80
LLCS 810-25780/2-A	Lab Control Sample	101	96	94	90
MBL 810-25780/1-A	Method Blank	95	89	93	76

Surrogate Legend

- PFHxA = 13C2 PFHxA
- PFDA = 13C2 PFDA
- HFPODA = 13C3 HFPO-DA
- d5NEFOS = d5-NEFOSAA





QC Sample Results

Client: Housatonic Basin Sampling & Testing
Project/Site: Great Barrington Fire Dist-1113000

Job ID: 810-30476-1

Method: 331.0 - Perchlorate (LC/MS/MS)

Lab Sample ID: MBL 810-25087/12
Matrix: Drinking Water
Analysis Batch: 25087

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MBL Result	MBL Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perchlorate	ND		0.050	0.012	ug/L			07/19/22 22:51	1

Lab Sample ID: LCS 810-25087/15
Matrix: Drinking Water
Analysis Batch: 25087

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perchlorate	10.0	9.84		ug/L		98	80 - 120

Lab Sample ID: LLCS 810-25087/14
Matrix: Drinking Water
Analysis Batch: 25087

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Perchlorate	0.0500	0.0501		ug/L		100	50 - 150


Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Lab Sample ID: MBL 810-25780/1-A
Matrix: Drinking Water
Analysis Batch: 25969

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 25780

Analyte	MBL Result	MBL Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorooctanesulfonic acid (PFOS)	ND		2.0	0.40	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluoroundecanoic acid (PFUnA)	ND		2.0	0.50	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluorohexanoic acid (PFHxA)	ND		2.0	0.40	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluorododecanoic acid (PFDoA)	ND		2.0	0.40	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluorooctanoic acid (PFOA)	ND		2.0	0.40	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluorodecanoic acid (PFDA)	ND		2.0	0.50	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluorohexanesulfonic acid (PFHxS)	ND		2.0	0.50	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluorobutanesulfonic acid (PFBS)	ND		2.0	0.40	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluoroheptanoic acid (PFHpA)	ND		2.0	0.40	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluorononanoic acid (PFNA)	ND		2.0	0.50	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluorotetradecanoic acid (PFTeDA)	ND		2.0	0.60	ng/L		07/25/22 11:13	07/27/22 21:53	1
Perfluorotridecanoic acid (PFTrDA)	ND		2.0	0.50	ng/L		07/25/22 11:13	07/27/22 21:53	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND		2.0	0.50	ng/L		07/25/22 11:13	07/27/22 21:53	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND		2.0	0.60	ng/L		07/25/22 11:13	07/27/22 21:53	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND		2.0	0.50	ng/L		07/25/22 11:13	07/27/22 21:53	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND		2.0	0.50	ng/L		07/25/22 11:13	07/27/22 21:53	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND		2.0	0.50	ng/L		07/25/22 11:13	07/27/22 21:53	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND		2.0	0.61	ng/L		07/25/22 11:13	07/27/22 21:53	1
Surrogate	MBL %Recovery	MBL Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C2 PFHxA	95		70 - 130				07/25/22 11:13	07/27/22 21:53	1

Eurofins Eaton South Bend



QC Sample Results

Client: Housatonic Basin Sampling & Testing
 Project/Site: Great Barrington Fire Dist-1113000

Job ID: 810-30476-1

Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS) (Continued)

Lab Sample ID: MBL 810-25780/1-A
Matrix: Drinking Water
Analysis Batch: 25969

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 25780


Surrogate	MBL MBL		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C2 PFDA	89		70 - 130	07/25/22 11:13	07/27/22 21:53	1
13C3 HFPO-DA	93		70 - 130	07/25/22 11:13	07/27/22 21:53	1
d5-NEIFOSAA	76		70 - 130	07/25/22 11:13	07/27/22 21:53	1

Lab Sample ID: LLCS 810-25780/2-A
Matrix: Drinking Water
Analysis Batch: 25969

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 25780

Analyte	Spike Added	LLCS LLCS		Unit	D	%Rec	%Rec Limits
		Result	Qualifier				
Perfluorooctanesulfonic acid (PFOS)	1.92	2.00		ng/L		104	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.92	1.80	J	ng/L		94	50 - 150
Perfluorohexanoic acid (PFHxA)	1.92	1.86	J	ng/L		97	50 - 150
Perfluorododecanoic acid (PFDoA)	1.92	1.74	J	ng/L		91	50 - 150
Perfluorooctanoic acid (PFOA)	1.92	1.91		ng/L		100	50 - 150
Perfluorodecanoic acid (PFDA)	1.92	1.76	J	ng/L		92	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.92	1.80	J	ng/L		94	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.92	1.84	J	ng/L		96	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.92	1.87	J	ng/L		98	50 - 150
Perfluorononanoic acid (PFNA)	1.92	1.96		ng/L		102	50 - 150
Perfluorotetradecanoic acid (PFTeDA)	1.92	1.55	J	ng/L		81	50 - 150
Perfluorotridecanoic acid (PFTTrDA)	1.92	1.81	J	ng/L		95	50 - 150
N-methylperfluorooctanesulfonamide acetic acid (NMeFOSAA)	1.92	1.54	J	ng/L		80	50 - 150
N-ethylperfluorooctanesulfonamide acetic acid (NEtFOSAA)	1.92	1.66	J	ng/L		86	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	1.92	1.79	J	ng/L		94	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	1.92	1.70	J	ng/L		89	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	1.92	1.71	J	ng/L		89	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.92	1.81	J	ng/L		94	50 - 150

Surrogate	LLCS LLCS		Limits
	%Recovery	Qualifier	
13C2 PFHxA	101		70 - 130
13C2 PFDA	96		70 - 130
13C3 HFPO-DA	94		70 - 130
d5-NEIFOSAA	90		70 - 130



QC Association Summary

Client: Housatonic Basin Sampling & Testing
 Project/Site: Great Barrington Fire Dist-1113000

Job ID: 810-30476-1

LCMS

Analysis Batch: 25087

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-30476-1	POE Post Green River PH 01G	Total/NA	Drinking Water	331.0	
MBL 810-25087/12	Method Blank	Total/NA	Drinking Water	331.0	
LCS 810-25087/15	Lab Control Sample	Total/NA	Drinking Water	331.0	
LLCS 810-25087/14	Lab Control Sample	Total/NA	Drinking Water	331.0	

Prep Batch: 25780

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-30476-1	POE Post Green River PH 01G	Total/NA	Drinking Water	537.1 DW	
MBL 810-25780/1-A	Method Blank	Total/NA	Drinking Water	537.1 DW	
LLCS 810-25780/2-A	Lab Control Sample	Total/NA	Drinking Water	537.1 DW	


Analysis Batch: 25969

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-30476-1	POE Post Green River PH 01G	Total/NA	Drinking Water	537.1	25780
MBL 810-25780/1-A	Method Blank	Total/NA	Drinking Water	537.1	25780
LLCS 810-25780/2-A	Lab Control Sample	Total/NA	Drinking Water	537.1	25780

Analysis Batch: 26291

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-30476-1	POE Post Green River PH 01G	Total/NA	Drinking Water	PFAS6	





Lab Chronicle

Client: Housatonic Basin Sampling & Testing
Project/Site: Great Barrington Fire Dist-1113000

Job ID: 810-30476-1

Client Sample ID: POE Post Green River PH 01G

Lab Sample ID: 810-30476-1

Date Collected: 07/12/22 09:47

Matrix: Drinking Water


Date Received: 07/14/22 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	331.0		1	25087	07/20/22 03:09	ST	EA SB
Total/NA	Prep	537.1 DW			25780	07/25/22 11:13	SS	EA SB
Total/NA	Analysis	537.1		1	25969	07/27/22 23:18	MH	EA SB
Total/NA	Analysis	PFAS6		1	26291	07/28/22 15:42	RD	EA SB

Laboratory References:

EA SB = Eurofins Eaton South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777





Accreditation/Certification Summary

Client: Housatonic Basin Sampling & Testing
Project/Site: Great Barrington Fire Dist-1113000

Job ID: 810-30476-1

Laboratory: Eurofins Eaton South Bend


Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Massachusetts	State	M-IN035	06-30-23

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
PFAS6		Drinking Water	PFAS Total





Method Summary

Client: Housatonic Basin Sampling & Testing
Project/Site: Great Barrington Fire Dist-1113000

Job ID: 810-30476-1

Method	Method Description	Protocol	Laboratory
331.0	Perchlorate (LC/MS/MS)	EPA	EA SB
537.1	Perfluorinated Alkyl Acids (LC/MS)	EPA	EA SB
PFAS6	PFAS6	EPA	EA SB
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA SB


Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA SB = Eurofins Eaton South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777






Sample Summary

Client: Housatonic Basin Sampling & Testing
Project/Site: Great Barrington Fire Dist-1113000

Job ID: 810-30476-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
810-30476-1	POE Post Green River PH 01G	Drinking Water	07/12/22 09:47	07/14/22 09:00	1113000

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15



SAMPLE COLLECTION RECORD | CHAIN OF CUSTODY | EUROFINS EATON ANALYTICAL




PWS NAME: GREAT BARRINGTON FIRE DIST			80 RUN WAY LEE, MA 01238 (413)248-4622	
PWS ID: 1113000			HBST P.O. # 1113000-220712	
PWS TOWN: Great Barrington			# of WO: ####	
PWS CLASS: COM				

SAMPLE INFORMATION							FIELD RECORDED			MICRO BIOLOGY		CHEMICAL ANALYSIS												
ID	SAMPLE TYPE	BACTERIA DEP ID	Chem Sample ID	LOCATION DESCRIPTION	DATE/TIME	SAMPLER	Field Temp C	Field pH	Field Turbidity (NTU)	CH2 Res (Free)	BACTERIA HPC	BACTERIA 922B P/A	BACTERIA 9223 QT	Perchlorate	PFAS 537.1	PFAS Blank								Preserved Na2S2o3
	[RS]	[EP1]	[10000]	POE POST GREEN RIVER PH 01G -	7/12/22 9:47 AM	Erick Bartlett								X	X	X								




810-30476 Chain of Custody

1.2
1.0
18

CUSTODY TRANSFER		DATE/TIME	NOTES
SAMPLER		7-13-22 10:30	
RECEIVED			
RELINQUISHED			
RECEIVED		7-14-22 (PUC)	
RELINQUISHED			

Note: Submit via EDEP unless designated Private or otherwise noted. Email report to: Admin@HousatonicBasin.com. Lab testing shall be in compliance with all State and Federal Drinking Water and applicable regulations.



Login Sample Receipt Checklist

Client: Housatonic Basin Sampling & Testing

Job Number: 810-30476-1

Login Number: 30476


List Source: Eurofins Eaton South Bend

List Number: 1

Creator: DePriest, Kellie

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	





Client Sample Results

Client: Housatonic Basin Sampling & Testing
 Project/Site: Great Barrington Fire Dist

Job ID: 810-20752-1

Client Sample ID: POE Post Green River PH 01G

Lab Sample ID: 810-20752-1

Date Collected: 04/12/22 09:15

Matrix: Drinking Water

Date Received: 04/13/22 09:30

PWSID Number: 1113000

Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorooctanesulfonic acid (PFOS)	0.54	J	1.9	0.38	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluoroundecanoic acid (PFUnA)	ND		1.9	0.47	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluorohexanoic acid (PFHxA)	ND		1.9	0.38	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluorododecanoic acid (PFDoA)	ND		1.9	0.38	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluorooctanoic acid (PFOA)	0.81	J	1.9	0.38	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluorodecanoic acid (PFDA)	ND		1.9	0.47	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluorohexanesulfonic acid (PFHxS)	ND		1.9	0.47	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluorobutanesulfonic acid (PFBS)	ND		1.9	0.38	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluoroheptanoic acid (PFHpA)	ND		1.9	0.38	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluorononanoic acid (PFNA)	ND		1.9	0.47	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluorotetradecanoic acid (PFTeDA)	ND		1.9	0.57	ng/L		04/20/22 08:25	04/20/22 23:00	1
Perfluorotridecanoic acid (PFTrDA)	ND		1.9	0.47	ng/L		04/20/22 08:25	04/20/22 23:00	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND		1.9	0.47	ng/L		04/20/22 08:25	04/20/22 23:00	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEFOSAA)	ND		1.9	0.57	ng/L		04/20/22 08:25	04/20/22 23:00	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND		1.9	0.47	ng/L		04/20/22 08:25	04/20/22 23:00	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND		1.9	0.47	ng/L		04/20/22 08:25	04/20/22 23:00	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND		1.9	0.47	ng/L		04/20/22 08:25	04/20/22 23:00	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND		1.9	0.58	ng/L		04/20/22 08:25	04/20/22 23:00	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C2 PFHxA	99		70 - 130				04/20/22 08:25	04/20/22 23:00	1
13C2 PFDA	95		70 - 130				04/20/22 08:25	04/20/22 23:00	1
13C3 HFPO-DA	98		70 - 130				04/20/22 08:25	04/20/22 23:00	1
d5-NEFOSAA	87		70 - 130				04/20/22 08:25	04/20/22 23:00	1

Method: PFAS6 - PFAS6

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
PFAS Total	ND		2.00	0.500	ng/L			04/20/22 08:25	1



Surrogate Summary

Client: Housatonic Basin Sampling & Testing
 Project/Site: Great Barrington Fire Dist

Job ID: 810-20752-1

Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		PFHxA (70-130)	PFDA (70-130)	HFPODA (70-130)	d5NEFOS (70-130)
810-20752-1	POE Post Green River PH 01G	99	95	98	87
LCS 810-17215/3-A - RA	Lab Control Sample	105	96	101	73
LLCS 810-17215/2-A	Lab Control Sample	104	94	99	84
MBL 810-17215/1-A	Method Blank	100	99	96	86

Surrogate Legend

PFHxA = 13C2 PFHxA

PFDA = 13C2 PFDA

HFPODA = 13C3 HFPO-DA

d5NEFOS = d5-NEFOSAA

